

ADDENDUM #2 – MARCH 25, 2024

RE: NORTH BEND SCHOOL DISTRICT
North Bay School Kitchen Remodel
Project #23.87

FROM: HGE ARCHITECTS, Inc.
333 South 4th Street
Coos Bay, Oregon 97420
541-269-1166



TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original Documents dated February 2024, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of **ONE (1)** page(s) together with the no attachments:

CHANGES TO DRAWINGS:

- 1. Sheet A5.1 DETAILS:**
 - a. **Details 1/A5.1 and 3/A5.1.** - Delete 1/2" x 4" anchor bolts at 2x6 P.T. embedded nailer.
- 2. Sheet A3.1 BUILDING SECTIONS:**
 - a. **SECTION 1/A3.1** - Revise ceiling height in cooler from 8'-6" to "8'-0" min, based on nominal panel sizes".
- 3. ADD:** Provide thermal break at the common wall between Cooler and Freezer similar to Detail 3/A5.1.

SUBSTITUTION APPROVALS: None.

END OF ADDENDUM #2