


**ADDENDUM #2 – 12/2/24**

**RE: CTCLUSI**  
Florence Clinic Renovation  
**Project #24.011**

**FROM: HGE ARCHITECTS, Inc.**  
333 South 4<sup>th</sup> Street  
Coos Bay, Oregon 97420  
541-269-1166



**TO: Prospective Bidders**

This Addendum forms a part of the Contract Documents and modifies the original Documents dated November 2024, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of **TWO (2)** page(s) together with the following attachments:

- **None**

**CHANGES TO DRAWINGS:**

- 1. Sheet A5.1 Details, Detail 4:** At Acoustical Ceiling note, REPLACE “(2) layers 1/2” gyp. bd.” WITH “(2) layers 1/2” acoustic sound dampening gyp. bd.” Refer to Section 09-2116, Paragraph 2.02.F for acoustic sound dampening ceiling gypsum board assembly.
- 2. Sheet A7.1 Schedules, Room Finish Schedule:** At Rooms #25 and #27 Ceiling Finish, REPLACE “ACT-1” with “GYP. BD. / PT-3.”

**SUBSTITUTION APPROVALS:**

| <b><u>SPECIFIED SECTION</u></b> | <b><u>SPECIFIED ITEM</u></b> | <b><u>APPROVED</u></b>  |
|---------------------------------|------------------------------|---|
| 26-5100 Lighting Fixtures       | D6                           | Lightolier by Signify, Model No. FD6R11XSCTX  |
| 26-5100 Lighting Fixtures       | L22                          | H.E. Williams, Inc., Model No. AP-22-L40/835-UNV-(L35)-DIM-UNV - 80 CRI<br><br>Lithonia, Model No. ENVX 2X2 HRG 4000LM 80CRI 35K MIN1 ZT MVOLT DWAM |

|                           |     |   |
|---------------------------|-----|---|
| 26-5100 Lighting Fixtures | L24 | H.E. Williams, Inc., Model No. AP-24-L50/835-UNV-(L57)-DIM-UNV - 80 CRI<br><br>Lithonia, Model No. ENVX 2X4 HRG 6000LM 80CRI 35K MIN1 ZT MVOLT DWAM |
| 26-5100 Lighting Fixtures | FP2 | H.E. Williams, Inc., Model No. BP-22-LS-8-CS-DIM-UNV  |
| 26-5100 Lighting Fixtures | FP4 | H.E. Williams, Inc., Model No. BP-24-LS-8-CS-DIM-UNV  |
| 26-5100 Lighting Fixtures | UC  | Elite Lighting, Model No. EU-LED-34-1300L-DIMXX-XX-30K/35K/40K-WH - 34"   |
| 26-5100 Lighting Fixtures | X1  | H.E. Williams, Inc., Model No. EXIT/EM/LP-R-WHT-D   |

**END OF ADDENDUM #2**